ABMA and ASME Guidelines for Steam Purity

ABMA for Water Tube Boilers

	Drum peessure,	Total dissolved solids ^b in boiler water, ppm (max.)	Total Alkalinity ^c in boiler water, ppm	Suspended solids in boiler water, ppm (max.)	Total dissolved solids ^{c,e} in steam, ppm (max. expected value)
Drum-type boilers	0-300	700-3500	140-700	15	0.2-1.0
	301-450	600-3000	120-600	10	0.2-1.0
	451-600	500-2500	100-500	8	0.2-1.0
	601-750	200-2000	40-400	3	0.1-0.5
	751-900	150-1500	30-300	2	0.1-0.5
	901-1000	125-1250	25-250	1	0.1-0.5
	1001-1800	100	variable ^d	1	0.1
	1801-2350	50	variable ^d	N/A	0.1
	2351-2600	25	variable ^d	N/A	0.05
	2601-2900	15	variable ^d	N/A	0.05
Once-through boilers	1400 & above	0.05	N/A	N/A	0.05

^a Reprinted (with permission) from "Boiler Water Limits and Steam Purity Recommendations for Watertube Boilers," American Boiler Manufacturers Association, 1982.

Feed/Boiler Water Limits Review use for example ASME Consensus table 3:

Drum Operating Pressure psig (MPa)	0 - 300 (0 - 2.07)
Feedwater	0 - 300 (0 - 2.07)
DO ppm (mg/l) O ₂ before oxygen scavenger	<0.007
Total iron ppm (mg/l) Fe	<0.1
Total copper ppm (mg/l) Cu	< 0.05
Total hardness ppm as CaCO3	<1.0
pH @ 25°C	8.3 to 10.5
Non-volatile TOC ppm (mg/l) C	<10
Oily matter ppm (mg/l)	<0.1
Boiler Water	
Silica ppm (mg/l) SiO ₂	<150
Total alkalinity ppm as CaCO ₃	< 700
Free OH alkalinity ppm as CaCO ₃	not specified
Conductance µS/cm) @ 25°C	< 7000
Conductance $\mu s/cm$; (a) 25 C	~/000

^b Actual values within the range reflect the TDS in the feedwater. Higher values are for high solids; lower values are for low solids in the feedwater.

^c Actual values within the range are directly proportional to the actual value of TDS of boiler water. Higher values are for high solids; lower values are for low solids in the boiler water.

^d Dictated by boiler water treatment.

^e These values are exclusive of silica.